

TEST REPORT

SCOPE OF WORK

Woven vinyl flooring

REPORT NUMBER

191106006SHF-005

TEST DATE(S)

2019-11-06 - 2019-11-21

ISSUE DATE

2019-11-21

PAGES


5

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(May 1, 2019)

© 2019 INTERTEK

Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch



Test Report

Statement

- 1.This report is invalid without company's special seal for testing on assigned page.
- 2.This report is invalid without authorized person's signature.
- 3.This report is invalid where any unauthorized modification indicated.
- 4.Don't copy this report in partial (except full copy) without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.Any holder of this document is advised that this report is for the exclusive use of Intertek's Customer and is provided pursuant to the agreement between Intertek and its Customer. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report was made with due care within the limitation of a defined scope of work and on the basis of information, materials and instructions received from the Customer or its nominated third parties. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. The tests results are not intended to be a recommendation for any particular course of action. Customer is responsible for acting as it sees fit on the basis of such results.
- 6.Intertek's written consent is required to use Intertek's name or logo on the object, product or service being tested. The observations and test results in this report relate only to the sample under test. This report alone does not indicate that the item, product or service has passed any Intertek certification program.

Test Report

Issue Date: 2019-11-21

Intertek Report No. 191106006SHF-005

Test Type : Performance test, samples provided by the applicant.

Product Information

Product Name	Woven vinyl flooring	Brand	ECO BEAUTY
Sample Description	Good Condition	Sample Amount	1 PC
		Received Date	2019-11-06
Sample ID	Model	Specification	
S191106006SHF.005	ECO	/	

Test Methods And Standards

Test Standard	EN 13893:2002
Specification Standard	/
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

1. This report relates specifically to the sample(s) that were drawn and provided by the applicant or their nominated third party. The reported result(s) provide no warranty or verification on the sample(s) representing any specific goods and/or shipment and only relate to the sample(s) as received and tested.

Report Authorized



Mason Wang Jackie Zhou

Name: Mason Wang Name: Jackie Zhou

Title: Reviewer Title: Project Engineer

Test Report

Issue Date: 2019-11-21

Intertek Report No. 191106006SHF-005

Test Items, Method and Results:

Test Item: Dynamic coefficient of friction

Test Method: EN 13893:2002

Conditioning: Condition the test specimens at $(23 \pm 2)^{\circ}\text{C}$ and $(50 \pm 5)\%$ relative humidity for at least 24h

Test Condition:

Applied Mass: 9.92 kg

Test Speed: 0.25 m/s

Test Result:

Specimen	Length direction/Machine direction	Width direction/Across machine direction
1	0.66	0.68
2	0.65	0.67
3	0.66	0.68
Mean	0.66	0.68
Result	0.66	

Note: Express the result as the lower of the two mean values in each direction.

Test Report

Issue Date: 2019-11-21

Intertek Report No. 191106006SHF-005

Appendix A: Sample Received Photo



Revision:

NO.	Date	Changes	Author	Reviewer
191106006SHF-005	2019-11-21	First issue	Jackie Zhou	Mason Wang